

# **Child Care Facility Inspection Report**

LIBERTY HEAD START CENTER

License #: 7740

Director: MONICA ROBINSON

Inspection Date: 05/17/2023

Annual/Mid Inspection
Inspector: LeKesha Sandifer

## **Program Administration Violations Cited**

No violations cited

### **Kitchen Violations Cited**

No violations cited.

### **Nutritional Guidelines Violations Cited**

No violations cited.

## **Playground Violations Cited**

No violations cited

#### **Preschool Classroom Violations Cited**

4 Year - Classroom Number: 1

No violations cited.

Preschool Classroom - Classroom Number: 1

3 Year Old - Classroom Number: 2

No violations cited.

Preschool Classroom - Classroom Number: 2

#### 4-5 - Classroom Number: 3

1. **Out of Compliance:** Ceiling, Floor, and/or floor covering is properly installed, kept clean, in good condition, and in good repair. (Rule 1.11.1(8) Page 51)

#### Preschool Classroom - Classroom Number: 3

1. **POC:** Licensing official observed A/C unit not working in classroom 3 and Kitchen. Director stated a request has been submitted to have repairs done. Classroom temperature should not go above 78. Children should be placed in classroom 4 if the temperature is 78 or above. A call shall be made to licensing when repairs are completed.

**Person Responsible:** Director **Date for Completion:** 5/26/23

### Legend

COS: Corrected on SitePOC: Plan of Correction

# **Child Care Director Signature**

Klesha Dordy

**MSDH Licensure Representative Signature**