

Child Care Facility Inspection Report

CLIFTON PRESTON HEAD START

License #: 7707

Director: FELICIA HARNESS

Inspection Date: 08/15/2022

Annual/Mid Inspection

Inspector: Sharetha Bennett

Program Administration Violations Cited

1. **Out of Compliance:** Heating units, including water pipes and baseboard heaters hotter than 110°F are inaccessible to children by barriers or guards. (Rule 1.11.8(16) Page 58)

Plan of Correction

1. **POC:** While touring the facility it was observed in classroom room 2 air conditioner not properly cooling the classroom. Director has put in a work order to have unit repaired.

Person Responsible: Felicia Harness **Date for Completion:**

Kitchen Violations Cited

No violations cited.

Nutritional Guidelines Violations Cited

No violations cited.

Playground Violations Cited

1. **Out of Compliance:** Tree limbs and other suspended hazards at least seven feet above play surfaces. Fence is free of brush and overgrowth. (CPSC 3.5 Page 16)

Plan of Correction

1. **POC:** Director will contact maintenance to have tree limbs cut above play area. Once repaired picture will be provided to licensing official.

Person Responsible: Felicia Harness **Date for Completion:** 8.19.22

Preschool Classroom Violations Cited

Room 2 - Classroom Number: 2

No violations cited.

Preschool Classroom - Classroom Number: 2

Legend

COS: Corrected on SitePOC: Plan of Correction

Child Care Director Signature

France Francess

MSDH Licensure Representative Signature

