



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 3Date 8/24/17

Name	<u>Tiny Tots Child Development Center</u>	License No.	<u>Pending</u>
Address	<u>712 N. Chrisman Ave Cleveland, MS 38732</u>		
Purpose	<u>Initial/TA</u>	Director	<u>Mary Livingston</u>
Mileage Start		Mileage End	
County	<u>Bolivar</u>	Telephone No.	<u>662.846.6699</u>
Time In	<u>9:25</u>	Time Out	
		Total Time	

Findings/Comments This visit is for an initial inspection for a child care license.Technical assistance was provided on the following.Building: Observed portable sinks in six classrooms. L.O. informed that sinks would be ran by upper management for use, since sinks had been installed and talk had already taken place between L.O. Lee and owner.Windows in three classrooms will need barrier at least four feet high when measured from the floor. - Rule 1.11.1(11). Observed windows without barriers.Playground: Observed concrete footing on fence not covered. Concrete footing should be located at least six inches below ground surface. - Rule 1.10.2(2). Bolts on playground fence exposed more than two threads and will need to be cut back. - Rule 1.11.9(5).The facility maximum capacity will be 105 due to toilet and handwashing sinks.A temporary child care license will be issued when facility submits overdue monetary penalty of \$600.00 from March 2017 and license fee of \$350.00.If any questions or concerns please call 662.455.9429."Class I and II violations may result in a monetary penalty. Repeated violations may result in the doubling of a monetary penalty, suspension, or revocation of the license."

Mary Livingston
Center Director/Designee/Individual

Mailenda Lee
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 3Date 8/28/17

Name Tiny Tots Child Development Center License No. Pending
 Address 712 Chrisman Ave Cleveland, MS 38738
 Center/Organization/Individual
 Purpose Possible Final Director Mary Livingston
 Mileage Start _____ Mileage End _____
 County Bolivar Telephone No. 662.846.6699
 Time In 11:28 Time Out 12:05 Total Time _____

Findings/Comments This visit is for possible final inspection for child care license.Observed ~~on~~ protective barrier being added to all windows four feet high.Portable sinks will be allowed for use in all rooms where diaper-wearing children will be housed. Sinks will be used for diapering only, all other needed items such as handwashing for lunch, washing cups/bottles will be done in bathrooms and kitchen.Observed concrete footing on playground fence being covered and all bolts cut down pass two threads.The facility's maximum capacity is (105).A temporary child care license will be issued for August 29, 2017 - Jan 31, 2018, upon receiving license fee of \$1350.00 and post due penalty of \$600.00.A customer service card was provided to Owner/Director Mary Livingston.If any questions please call 662-455-9429 or 601-364-2827."Class I and II violations may result in a monetary penalty. Repeated violations may result in the doubling of a monetary penalty, suspension, or revocation of the license."

Mary Livingston
 Center Director/Designee/Individual

Sharon B
 Child Care Representative

White Copy - Facility File
 Yellow Copy - Operator



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility Data Sheet

Facility Name Tiny Totz Date 8/24/17
 Physical Address 712 N. Chrisman Cleveland, MS
 Operator Mary Livingston Daytime Telephone Number _____
☒ Commercial Facility ☐ Occupied Residence _____ Year Building was constructed _____
 Total # of Floors 1 # of Floors Used for Child Care 1 # of Rooms 12 # of Rooms Used for Child Care 12
 Construction: Masonry ☒ Brick _____ Frame _____ Metal _____ Other _____

I. Building/Grounds

Mark: In = Incompliance with Regulations Out = Out of compliance with regulations NA = Does not apply

A. General

- | In | Out | NA | |
|-------------------------------------|-------------------------------------|-------------------------------------|--|
| ☒ | ☐ | ☐ | 1. Two (2) easily opened outward opening doors (minimum 32 inches wide) equipped with single action opening hardware. |
| ☒ | ☐ | ☐ | 2. Walls – ☐ clean ☐ repair ☐ paint ☐ replace |
| ☒ | ☐ | ☐ | 3. Floors – ☐ clean ☐ repair ☐ paint ☐ replace |
| ☒ | ☐ | ☐ | 4. Ceiling – ☐ clean ☐ repair ☐ paint ☐ replace |
| ☒ | ☐ | ☐ | 5. Plug covers on all outlets. |
| ☒ | ☒ | ☐ | 6. Barriers installed as needed – ☐ kitchen ☐ stairways ☒ windows ☐ porches ☐ other <u>Completed 8/28/17</u> |
| ☐ | ☐ | ☒ | 7. Handrails – ☐ steps ☐ landings ☐ toilets ☐ other _____ |
| ☒ | ☐ | ☐ | 8. Heating/cooling – ☐ gas ☐ electric ☐ other _____
Note – Non-electric heat/cool systems or appliances require carbon monoxide monitors to be installed as well as smoke detectors. All gas heaters must be vented to outdoors. |
| ☒ | ☐ | ☐ | 9. Unapproved heaters (must be removed). |
| ☒ | ☐ | ☐ | 10. Adequate, proper heating and/or cooling systems. |
| ☐ | ☒ | ☐ | 11. Child safe thermometers at child level in every room utilized by children. |
| ☒ | ☐ | ☐ | 12. Adequate lighting. Note – All lights must be shielded. |
| ☒ | ☐ | ☐ | 13. Telephone accessible to caregivers. |
| ☒ | ☒ | ☐ | 14. Individual compartments or hooks for each child. <u>Completed 8/28/17</u> |
| ☒ | ☒ | ☐ | 15. Diaper changing stations in all rooms housing children who are not toilet trained.
Note – Diaper changing stations must have hot and cold water and may not be used for any purpose except diapering. Number of diaper changing stations _____
<u>approved portable sinks 8/25/17</u> |
| ☒ | ☐ | ☐ | 16. Approved – ☐ waste water ☐ water supply |
| ☒ | ☐ | ☐ | 17. Emergency evacuation plan posted. |
| ☒ | ☐ | ☐ | 18. Hot and cold running water at all handwashing sinks. |
| ☐ | ☐ | ☐ | 19. Building constructed prior to 1965 has been tested for lead. |

B. Kitchen/Food Preparation Area

In Out NA

- ☒ ☐ ☐ 1. Adequate refrigeration with thermometer.
- ☒ ☐ ☐ 2. Adequate cooking appliances (stoves/microwaves/ovens)
Note - Number and Type must be based on menu evaluation and number of meals to be prepared.
- ☒ ☐ ☐ 3. Approved stove hood, vented to outside per fire codes.
- ☐ ☒ ☐ 4. Separate freezer when 50+ children are served.
- ☐ ☐ ☒ 5. Approved dishwasher. _____
- ☒ ☐ ☐ 6. Three (3) compartment sink.
- ☐ ☐ ☒ 7. Food preparation sink.
- ☐ ☐ ☒ 8. Mop sink.
- ☒ ☐ ☐ 9. Handwashing sink. Note - All sinks must have hot and cold water.

C. Grounds

In Out NA

- ☒ ☐ ☐ 1. Approved play area with fence.
- ☒ ☐ ☐ 2. All hazards including non-approved playground equipment removed.
- ☐ ☐ ☒ 3. Playground equipment approved before installation. *No playground equipment*
- ☒ ☐ ☐ 4. Playground completed before opening for business.
- ☒ ☐ ☐ 5. Safe arrival/departure areas.
- ☐ ☐ ☐ 6. Soil tested for lead.
- ☐ ☐ ☒ 7. Other _____

II. Furniture And Equipment**A. Furniture**

In Out NA

- ☒ ☒ ☐ 1. Appropriate *8/28/17*
- ☒ ☒ ☐ 2. Child size *8/28/17*
- ☒ ☒ ☐ 3. Adequate number *8/28/17*

B. Equipment

In Out NA

- ☐ ☐ ☒ 1. Approved location of laundry equipment
- ☒ ☐ ☐ 2. Recommended toys appropriate for ages of children are available.
- ☒ ☐ ☐ 3. Approved bedding - ☐ cribs ☐ cots ☐ pads

Note - 24 hour and night time care require bedding with minimum 3 inch mattresses.

III. Other

In Out NA

- ☒ ☐ ☐ Complies with local zoning, building and fire safety codes.

IV. Recommendations

M. J. Long
Operator/Center/Date

Shelby
Licensing Officer