

# **Child Care Facility Inspection Report**

FIRST UNITED METHODIST CHURCH EARLY LEARNING CENTER

License #: 1546

Director: NAOMI EDMONDS

Inspection Date: 02/01/2022

Annual/Mid Inspection
Inspector: Mary Hampton

## **Program Administration Violations Cited**

No violations cited

#### **Kitchen Violations Cited**

No violations cited.

#### Plan of Correction

1. **POC:** Based on observation while touring the kitchen counter to sink appears to be leaking water. Please consider repairing borders around to prevent further damages or slip hazards.

Person Responsible: Director/church Date for Completion:

### **Nutritional Guidelines Violations Cited**

No violations cited

## **Playground Violations Cited**

1. **Out of Compliance:** Appropriate surfing material is present and meets minimum required compressed loose-fill surfacing depths (e.g., 6 inches for shredded/recycled rubber; 9 inches for sand, pea gravel, wood mulch (non-CCA), and woodchips). (Appendix D 2.4 & 2.5 Page 8-10)

## Legend

COS: Corrected on SitePOC: Plan of Correction

## **Child Care Director Signature**

Acomican order

**MSDH** Licensure Representative Signature

Muy brown