



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility Inspection

County Hinds Date 1-14-20

Facility Name Jacob's Ladder Center For Learning License Number 25CDPFA-5699

Purpose Mid-Year Inspection/TA Capacity 60

All Items In Red Are Critical

	In	Out	COS	N/A
Qualified director present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper staff to child ratio present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Room and playground capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Center capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
License/complaint visible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Certified food manager	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Sanitation Approved

	In	Out	COS	N/A
Garbage and garbage bins maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vector control maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Waste water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Food service approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Possible Monetary Penalty

	Monetary Penalty
1. _____	\$ _____
2. _____	\$ _____
3. _____	\$ _____
4. _____	\$ _____
5. _____	\$ _____

	Age/Child/Staff Name
1.	Infants 4 Caregiver #1
2.	1 year olds 9 Caregiver #2 & #3
3.	2 year olds 10 Caregiver #4
4.	3-4 yr olds 10 Caregiver #5
5.	
6.	
7.	

Other Items - Must be corrected

	In	Out	COS	N/A
Children's belongings separated/stored	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Evacuation plans posted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Menus posted and served	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan of activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Building and Grounds

	In	Out	COS	N/A
Walls, ceilings, floors, toys, equipment clean and in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lighting approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating/cooling approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ventilation adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Glass approved and shielded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Telephone on premises, available, and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical outlets protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Large appliances located properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sinks and toilets working properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot water at all sinks, not to exceed 120°	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Children barred from kitchen	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vending machine snacks meet nutritional guidelines, if present	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exits, doors and fastening devices single action approved and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exits unobstructed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Required smoke detectors, carbon monoxide monitors, fire extinguishers and thermometers placed properly and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
First aid kits stocked and easily accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground area clean, shaded, well drained and equipped and fence in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground equipment meets standards	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Pool area clean, fenced, and adequately maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diaper changing stations adequate in number and each fully supplied (number <u>11</u>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Center Director/Individual Anta Rogers

Child Care Representative Debbie Bone



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 5

Date 1-14-20

Name	<u>Jacob's Ladder Center For Learning</u>	License No.	<u>25CDPFA-5699</u>
Address	<u>5753 Angle St. Jackson, MS 39206</u>		
Center/Organization/Individual			
Purpose	<u>Mid-Year Inspection/TA</u>	Director	<u>Linda Stuckey</u>
Mileage Start	<u>N/A</u>	Mileage End	<u>N/A</u>
County	<u>Hinds</u>	Telephone No.	<u>601-316-0278</u>
Time In	<u>9:40 am</u>	Time Out	<u>11:15 am</u>
		Total Time	<u>N/A</u>

Findings/Comments Upon arrival licensing official Denise Love, met with the Alternate Director Anita Rogers and stated the purpose of the visit.

* The Facility Building and Grounds was found with no critical violations.

* The Facility kitchen was found with no critical violations and will receive a letter grade.

* Technical Assistance provided to label open food that's been placed in the refrigerator as left over.

* There were 1 staff and 2 children 121 forms that need to be updated. The facility will have 14 days (1-28-20) to submit.

* An updated food ~~certification~~ certification, staff and children rosters

* Contact information - office: 601-364-2827 (all copies) were received
- email: denise.love@healthymississippi.com
- Fax #: 601-364-5058

A green survey card was left with the Alternate Director.

"Class I and II violations may result in a monetary penalty. Repeated violations may result in the doubling of a monetary penalty, suspension or revocation of the license."

Anita Rogers
Center Director/Designee/Individual

Denise Love
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator

Food Service Facility Inspection Results

PIMS ID 5699	Facility Name, Address Jacob's Ladder Center for Learning 5753 Angle St. Jackson, ms 39206	Date 1-14-20
------------------------	--	------------------------

CRITICAL VIOLATIONS

CORRECTION PLAN AND SCHEDULE

No critical violations noted.

The Facility will receive letter grade "A"

<input type="checkbox"/> 92020 Scheduled <input type="checkbox"/> 92030 Followup <input type="checkbox"/> 92040 Complaint <input type="checkbox"/> 92050 Consultation <input type="checkbox"/> 92070 Plan Review/Const. <input type="checkbox"/> 92080 No Inspection <input type="checkbox"/> 92090 Restaurant Training	<input type="checkbox"/> 92010 Permit No Charge <input type="checkbox"/> 92015 Permit 1 \$30.00 <input type="checkbox"/> 92011 Permit 2 \$100.00 <input type="checkbox"/> 92012 Permit 3 \$150.00 <input type="checkbox"/> 92013 Permit 4 \$200.00
Permit Date	Environmental Code
Please Remit within 10 days to:	

Linda D. Stuckey Tummy Safe
 Certified Manager Licence Number

Expires: September 9, 2024

Facility Signature <i>Anita Rogers</i>
Environmental Signature <i>Wendy Bone</i>

White Copy - Facility
 Yellow Copy - PIMS
 Pink Copy - Environmentalist

Child Care Licensure Playground Checklist

Center Name Jacob's Ladder Center For Learning Inspection Date 1-14-20

YES NO N/A

- ☒ ☐ ☐ 1. Playground fence less than 3 1/2" from surface. (Rule 1.11.9 (8), pg 60) In good repair, v no gaps? (Rule 1.11.9 (8), pg 60)
- ☒ ☐ ☐ 2. 2 entrances/exits, with one being remote from the building? (Rule 1.11.9 (8), pg 60)
- ☐ ☐ ☒ 3. Is surfacing adequate? If not, where is it inadequate? (CPSC, 2.4.2, pg 9-10 & 4.3)
No composite equipment
- ☒ ☐ ☐ 4. AC units, high-voltage cabling/wires inaccessible? (Rule 1.11.9 (5), pg 59)
- ☐ ☒ ☐ 5. No standing water present on playground or in/on playground equipment or walkwa (CPSC 2.4.2.2(5), pg 10 & Rule 1.11.11 (4), pg 61) Due to rain today
- ☒ ☐ ☐ 6. Toys & equipment in good repair? (none broken/deteriorating) (Rule 1.10.2 (2), pg 46)
- ☒ ☐ ☐ 7. Sidewalks provide smooth walking surface? (no trip hazards) (CPSC 3.6, pg 16-17)
- ☒ ☐ ☐ 8. All bolts on equipment & fence <2 threads beyond the nut? Are all bolts and fencin twists/wires facing away from the playground area? (Rule 1.11.9 (5), pg 59)
- ☒ ☐ ☐ 9. Tree limbs at least 7ft. above play surfaces? Is fence free of brush/overgrowth? (CP 3.4, 3.5, pg 16)
- ☐ ☐ ☒ 10. Are use zones adequate? If not, where are they inadequate? (CPSC 5.3.9, pg 41)
- ☐ ☐ ☒ 11. If swings are present, are S-hooks in good repair? If not, state deficiency (CPSC 3.2, 2.5.2, pg 1 & 5.3.8.1, pg 3)
- ☐ ☐ ☒ 12. If slide is present, is exit height/exit zone adequate? If not, state deficiency (CPSC 5.3.6.4-5 pg 36)
- ☐ ☐ ☒ 13. Are spring rockers a minimum of 6 ft. apart? (ASTM 9.5.1.2 & CPSC 5.3.7, pg 36)
- ☒ ☐ ☒ 14. Is age-appropriate equipment being used? If not, state which pieces are inappropriate (Rule 1.10.2 & CPSC 2.2.6)
Toys only
- ☒ ☐ ☐ 15. Is playground area clean & free of hazards? If not, state deficiency. (Rule 1.11.11 (1))
- ☒ ☐ ☐ 16. Is adequate shade present on the playground? (Rule 1.11.9 (7), pg 60 & CPSC 2.1.1)
- ☐ ☐ ☒ 17. Are concrete footings located at least 6" beneath the surface? (Rule 1.10.2 (2), pg CPSC 3.6, pg 16-17)
- ☐ ☐ ☒ 18. Is wood smooth? Documentation provided that wood has been properly treated. (2.5.5, pg 15)

Director

Amrita Rogers

Licensing Official

Deemise Bone