



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility Inspection Report

MID-TOWN HEAD START CENTER

License #: 1048

Director: No Director

Inspection Date: 12/12/2023

Annual/Mid Inspection

Inspector: Erica Jenkins

Program Administration Violations Cited

1. **Out of Compliance:** Current license is displayed in a conspicuous place. (Rule 1.2.10 Page 11)
2. **Out of Compliance:** Valid, up-to-date fire inspection form (#333) is on file. (Rule 1.2.5 Page 10)
3. **COS:** Facility has appropriate number of operational toilets and handwashing lavatories. A ratio of 1:15 is required. Each sink is supplied with hot and cold running water, soap, and individual towels for drying. Each toilet is supplied with toilet paper. (Rule 1.11.5 Page 56)

Kitchen Violations Cited

No violations cited.

Nutritional Guidelines Violations Cited

No violations cited.

Playground Violations Cited

1. **Out of Compliance:** Playground area is clean and free of hazards. (Rule 1.11.11 Page 61)
2. **Out of Compliance:** Adequate shade is present on playground area. (Rule 1.11.9(7) Page 60)

Preschool Classroom Violations Cited

E - Classroom Number: 1

1. **Out of Compliance:** Room is well lighted, ventilated, and free of hazardous or potentially hazardous conditions. (Rule 1.11.1(9) Page 51)

Preschool Classroom - Classroom Number: 1

F - Classroom Number: 2

1. **Out of Compliance:** Room is well lighted, ventilated, and free of hazardous or potentially hazardous conditions. (Rule 1.11.1(9) Page 51)

Preschool Classroom - Classroom Number: 2

G - Classroom Number: 7

1. **Out of Compliance:** Thermometers that are not hazardous to children are placed on interior walls at children's height. (Rule 1.11.8(9) Page 58)

Preschool Classroom - Classroom Number: 7

H - Classroom Number: 8

1. **Out of Compliance:** Evacuation route is posted in classroom. (Rule 1.4.6(d) Page 18)
2. **Out of Compliance:** Unused electrical outlets are covered by safety plug covers. (Rule 1.11.1 Page 52)

Preschool Classroom - Classroom Number: 8

D - Classroom Number: 9

1. **Out of Compliance:** Daily schedule is posted in classroom. (Rule 1.4.6(b) Page 18)
2. **Out of Compliance:** Evacuation route is posted in classroom. (Rule 1.4.6(d) Page 18)
3. **Out of Compliance:** Thermometers that are not hazardous to children are placed on interior walls at children's height. (Rule 1.11.8(9) Page 58)

Preschool Classroom - Classroom Number: 9

C - Classroom Number: 10

1. **Out of Compliance:** Daily schedule is posted in classroom. (Rule 1.4.6(b) Page 18)
2. **Out of Compliance:** Evacuation route is posted in classroom. (Rule 1.4.6(d) Page 18)

Preschool Classroom - Classroom Number: 10

B - Classroom Number: 11

1. **Out of Compliance:** Daily schedule is posted in classroom. (Rule 1.4.6(b) Page 18)
2. **Out of Compliance:** Evacuation route is posted in classroom. (Rule 1.4.6(d) Page 18)

Preschool Classroom - Classroom Number: 11

A - Classroom Number: 12

1. **Out of Compliance:** Daily schedule is posted in classroom. (Rule 1.4.6(b) Page 18)
2. **Out of Compliance:** Thermometers that are not hazardous to children are placed on interior walls at children's height. (Rule 1.11.8(9) Page 58)

Preschool Classroom - Classroom Number: 12

Legend

- COS: Corrected on Site
- POC: Plan of Correction

Child Care Director Signature

No Director
Present

MSDH Licensure Representative Signature

Lucas
Jenkins
J. Woods