

Mississippi State Department of Health
CHILD CARE SURVEY DATA — PART I

COUNTY Hinds SANITARIAN I.D. NO. _____
DATE 8/29/00
FACILITY OPERATOR NAME Breath of Life
FACILITY NAME Lynch + Tapelo St., Jackson
ADDRESS/PHONE _____

FAMILY DAY CARE HOME ☐

DAY CARE CENTER ☒

- I. A. Amount of usable indoor square feet measured: 4623.80
B. Amount of usable outdoor square feet measured: 5775 ÷ 3
C. Number of toilets noted: ~~5775~~ 3
D. Number of lavatories noted: 3

Maximum number of allowable children 45

The following indicated items shall be completed for licensure:

II. Building and Grounds
Outdoor Play Area

- ☒ A. Install two (2) remote outward opening doors (minimum 32 inches wide). One near the front and one at the rear.
☒ B. Clean: (a) walls (b) floors (c) ceiling.
☒ C. Repair walls. hole in wall, nails in wall, seal around windows + paint
____ D. Paint walls.
☒ E. Replace floor. finish floor covering
☒ F. Install plug covers in all wall outlets. + face plates
☒ G. Install an approved play area with a barrier of a minimum height of four (4) feet containing at least seventy (70) square feet per child.
☒ H. Clean play area of hazardous or potentially hazardous objects.
☒ I. Install barriers at kitchen entrance.
____ J. Install barriers at stairways.
____ K. Install handrails at steps.
☒ L. Install barriers at low windows or full length glass doors.

III. Kitchen

- ☒ A. In the kitchen, install:
____ ☒ (a) A three (3) compartment sink.
____ (b) A dishwasher with a sanitizing cycle.
____ B. Install a two (2) compartment sink.
☒ C. Install a separate handwashing lavatory.
☒ D. Install a hood over the stove vented to the outside air.
☒ E. Provide overhead light with a shield.
____ F. Remove laundry equipment from the kitchen.
☒ G. Install adequate refrigeration with thermometer provided.

CHILD CARE SURVEY DATA — PART II

IV. Heating*window units heat/cool*

- _____ A. Install proper heating (see page 20 of the "Regulations Governing Licensure of Child Care Facilities").

Gas heaters, if used, must meet the following requirements:

The flame shall be recessed and enclosed with a guard so designed that clothing or other inflammable material cannot be ignited.

Each heater shall be equipped with automatic shut-off valve.

Each heater shall be vented to the outside.

Each heater shall be approved by Underwriters Laboratory of American Gas Association.

- _____ B. Remove unapproved gas heaters throughout the building (space heaters).
- _____ C. Protect floor furnaces with a barrier.
- ☒ D. Heating shall be adequate to maintain a temperature between 68 degrees and 72 degrees at child height. Accurate thermometers shall be hung throughout the facility.

V. Furniture and Equipment

- ☒ A. Equipment shall be sturdy and safe and shall not have sharp edges, splinters, protruding nails, etc.
- ☒ B. Paint on toys shall be lead-free and nonpoisonous.
- ☒ C. Chairs and tables shall be of a size appropriate to the size of the children.
- ☒ D. Individual hooks or compartments provided for each child.

VI. Fire Safety*Recommend cubbies*

- ☒ A. An adequate number of ABC type fire extinguishers provided, hung, tagged, and signed by a competent inspector.
- ☒ B. Each employee should understand procedure for using extinguishers.
- ☒ C. Post fire evacuation plan.

VII. General

- _____ A. Additional lighting must be installed.
- ☒ B. Install a telephone.
- ☒ C. Individual cots or nap pads (waterproof) must be provided.
- ☒ D. Facility in compliance with local fire, building and zoning ordinances.
- ☒ E. Provide diaper changing area. *possibly two*

VIII. Other

- 1) *Install changing table w/ Hot + cold water in all rooms w/ diaper wearing children*
- 2) *Add 3 toilets + 3 lavatories for max of 77.*

IX. In Addition, the Following Requirements Shall be Met:

1. The information in the section labeled Records and Reports of the Regulations Governing the Licensure of a Child Care Facility must be kept on file at all times.
2. A certificate of inspection and approval by the fire department and the local health department must be obtained.
3. Notice of compliance with local zoning and building ordinances if applicable.

* This inspection is valid for three (3) months only.

Patricia Lewis
Received by

Kae Covington
H P Environmentalist

CHILD CARE ENCOUNTER

Name Breath of Life (new chr.) County Hinds
(Center\Organization\Individual)
 Address 2405 Lynch St. Date 8/29/00
Jackson, MS
 Phone _____ Time 10:15
 License Number proposed

REQUEST\ENCOUNTER: Re: New Facility

Spoke w/ Ms. Lewis before leaving the office. Lewis
stated that she was leaving "NOW" (10:00 AM)
The Heat is unbearable, 10:35,

- 1- Measured
- 2- prepared Survey Data Report
- 3- prepared Cap worksheet
- 4- provided Technical Assistance

COMMENTS:

~~Please phone for another appointment.~~

- ★ Work must be done + ready for inspection by 9/15/00
 (excluding kitchen) (excluding 3rd playground)
- ★ Playground #3, kitchen, + ~~toilets~~ 3 additional toilets must be
 completed by 11/10/00.

Patricia Lewis
(Center Director\Individual)

Kae Covington
(Child Care Representative)