

Pending

Mississippi State Department of Health
CHILD CARE SURVEY DATA — PART I

COUNTY Washington
DATE 4/23/92

SANITARIAN I.D. NO. 1307

FACILITY OPERATOR NAME Dolores Townes
FACILITY NAME Little Rascals Nursery & Daycare ctr.
ADDRESS/PHONE 405 S Beauchamp
Greenville, Ms

FAMILY DAY CARE HOME ☐

DAY CARE CENTER ☒

- I. A. Amount of usable indoor square feet measured: 650.75
B. Amount of usable outdoor square feet measured: 7566
C. Number of toilets noted: 2
D. Number of lavatories noted: 2
- Maximum number of allowable children 19 25
- Handwritten calculations:
 $11 \times 10.5 = 115.5$
 $12 \times 11 = 132$
 $22 \times 8.5 = 187$
 $4 \times 13.5 = 54$
 $9.5 \times 9.5 = 90.25$
 $11 \times 9.5 = 104.5$
 $12.5 \times 11 = 137.5$
 $97 \times 78 = 7566$
 $187 = 108$
 865.75
 $6 \times 75 = 45$
 $650.75 = 19(25)$

The following indicated items shall be completed for licensure:

II. Building and Grounds
Outdoor Play Area

- ☒ A. Install two (2) remote outward opening doors (minimum 32 inches wide). One near the front and one at the rear.
☒ B. Clean: (a) walls (b) floors (c) ceiling.
☐ C. Repair walls.
☐ D. Paint walls.
☒ E. Replace floor. Front Area
☒ F. Install plug covers in all wall outlets.
☒ G. Install an approved play area with a barrier of a minimum height of four (4) feet containing at least seventy (70) square feet per child. Shrubs
☒ H. Clean play area of hazardous or potentially hazardous objects. (Shed-etc) Ants
☒ I. Install barriers at kitchen entrance.
☐ J. Install barriers at stairways.
☐ K. Install handrails at steps.
☒ L. Install barriers at low windows or full length glass doors.

III. Kitchen

- ☒ A. In the kitchen, install:
 — (a) A three (3) compartment sink.
 — (b) A dishwasher with a sanitizing cycle.
☒ B. Install a two (2) compartment sink.
☒ C. Install a separate handwashing lavatory.
☒ D. Install a hood over the stove vented to the outside air. >
☐ E. Provide overhead light with a shield.
☒ F. Remove laundry equipment from the kitchen.
☒ G. Install adequate refrigeration with thermometer provided.

IV. Heating

- ☒ A. Install proper heating (see pages 5 - 6 of the "Regulations Governing Licensure of Child Care Facilities").

Gas heaters, if used, must meet the following requirements:

The flame shall be recessed and enclosed with a guard so designed that clothing or other inflammable material cannot be ignited.

Each heater shall be equipped with automatic shut-off valve.

Each heater shall be vented to the outside.

Each heater shall be approved by Underwriters Laboratory of American Gas Association. ✓

- ☒ B. Remove unapproved gas heaters throughout the building (space heaters).

- ☒ C. Protect floor furnaces with a barrier. *space heater (wall)*

- ☒ D. Heating shall be adequate to maintain a temperature between 68 degrees and 72 degrees at child height. Accurate thermometers shall be hung throughout the facility.

V. Furniture and Equipment

- ☒ A. Equipment shall be sturdy and safe and shall not have sharp edges, splinters, protruding nails, etc.
- ☒ B. Paint on toys shall be lead-free and nonpoisonous.
- ☒ C. Chairs and tables shall be of a size appropriate to the size of the children.
- ☒ D. Individual hooks or compartments provided for each child.

VI. Fire Safety

- ☒ A. An adequate number of ABC type fire extinguishers provided, hung, tagged, and signed by a competent inspector.
- ☒ B. Each employee should understand procedure for using extinguishers.
- ☒ C. Post fire evacuation plan.

VII. General

- ☒ A. Additional lighting must be installed.
- ☒ B. Install a telephone.
- ☒ C. Individual cots or nap pads (waterproof) must be provided.
- ☒ D. Facility in compliance with local fire, building and zoning ordinances.
- ☒ E. Provide diaper changing area.

VIII. Other

Call me for follow up insp

IX. In Addition, the Following Requirements Shall be Met:

1. The information on pages eleven (11) and twelve (12), Section J. Records of the Regulations Governing the Licensure of a Child Care Facility must be kept on file at all times.
2. A certificate of inspection and approval by the fire department and the local health department must be obtained.
3. Notice of compliance with local zoning and building ordinances if applicable.

Lafayette Townes
Received By

Ron Hadellacher
Sanitarian
P.H. Environmentalist II