



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 6Date 04/08/2021

Name <u>Charles L Young</u>	License No. _____
Address <u>2211 11th Ave</u>	Center/Organization/Individual <u>Meridian, Ms 39301</u>
Purpose <u>Initial Inspection</u>	Director <u>Thames</u>
Mileage Start _____	Mileage End _____
County <u>Lauderdale</u>	Telephone No. _____
Time In _____	Time Out _____ Total Time _____

Findings/Comments

The licensing official came to conduct a Initial Inspection. The following repairs need to be completed:

- all classrooms need base boards in bathrooms
- boys/girls bathroom hot water needs to be turned up
- Unit D toilet will not flush
- Unit H no hot water in bathroom
- Unit I no hot water in left sink
- Unit K no hot water in left sink
- Unisex bathroom toilet needs repaired
- playground needs surfacing
- multipurpose room ceiling needs to be repaired
- Kitchen needs to be sanitize and clean
- Kitchen needs hot water for handwashing sink
- staff need LOS⁽⁵⁾ fire⁽²⁾ form's (3)

Please contact licensing official when all repairs have been completed and are in compliance with MSDH regulations.

The facility can not open ~~with a~~ until all repairs have been made. A follow up inspection will be conducted.

Upon facility review, (5) five staff we found without Letters of Suitability and (3) staff we found without 121 forms.

Ilander Fortner
Center Director/Designee/Individual

L. Everett
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator