



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 5Date 10.1.2020

Name <u>Arise and Shine</u>	License No. <u>Pending</u>
Address <u>306 W Cayuga Street Crystal Springs, MS</u>	
Purpose <u>Possible Final</u>	Director <u>Christina Fletcher</u>
Mileage Start _____	Mileage End _____
County <u>Copiah</u>	Telephone No. <u>(601) 951-7864</u> <u>281-8212</u>
Time In <u>10:15</u>	Time Out _____ Total Time _____

Findings/Comments Arrived at the facility to conduct a possible final inspection. Met w/ director.

After a walk-through of the facility, facility has completed most of the repairs marked out on form "286".

Correction needed to complete final inspection
light fixture need to have shatter proof bulbs
and glass surrounding fixture need to be shatter proof
or removed.

* threshold in the classroom 1 needs repairing
* Edges on divider separating the classroom need to
be soften, to avoid injury.

* Playground still has to have brush/overgrowth that has
to be removed. * Close in HVAC unit

* Food manager Certification

* Water/waste water

* Zoning

Christina Fletcher
Center Director/Designee/Individual

Duffany S.
Child Care Representative

LO- Licensing Official
COS-Corrected on Site
TA-Technical Assistance
POC-Plan of Correction
LOS-Letter of Suitability