



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District

5

Date

10.20.2021

Name

Florence First Daycare

License No.

pending

Address

2396 Highway 49 South Florence, MS

Center/Organization/Individual

Purpose

Initial

Director

Angelica Killingsworth

Mileage Start

Mileage End

County

Rankin

Telephone No.

601 717 2548

Time In

12:00 PM

Time Out

2:35 PM

Total Time

Findings/Comments

Upon arrival licensing officials and supervisors met with owner/director Angelica Killingsworth.

The purpose of this visit was to conduct an initial inspection for the facility.

The following was observed and will have to be in compliance (corrected) before a child care license is issued.

-letter stating no afterschoolers will be enrolled at child care facility. If the owner/director changes her mind she will contact the licensing officials before making any changes.

-Licensing officials recommend all shelves in classrooms are anchored including high chair tables due to safety concerns.

-Classroom #1 - floor covering, border on wall (hole in wall), outlet covered (plugged in) Rule 1.11.1(8), 1.11.1(12), 1.11.1(10)

-Classroom #2 - ceiling tile not properly installed. Rule 1.11.1(8)

-Classroom #3 - Rule 1.11.3(1) door should weather tight & water tight. Rule 1.11.1(12) - hole in wall should be repaired.

-Classroom #4 - recommendation to anchor shelves water shall not exceed 120° Rule 1.11.5(4) (please check water temperature)

AK Killingsworth
Center Director/Designee/Individual

Angelica Killingsworth
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter (Continuation)

Date 10.20.2021

Facility Name

Florence First Daycare

License No.

pending

in all classrooms.

Classroom #5 - Extension cords shall not be Rule 1.11.1(17)
accessible (refrigerator cord) gaps in ceiling tiles rule 1.11.1(8)

classroom #6 - Close gaps in ceiling tile (Rule 1.11.1(8), gaps
on pole gap between outlet covers Rule 1.11.1(12) walls should
be free of chipped paint. anchor shelves

Playground - Rule 1.11.9(5) Playground should be free of
hazards. 1) ant bed removed 2) gap in fence (bottom) 3) remove
gravel 4) boots cut back 2 threads 5) back on fence 6) remove
playground equipment openings on fence shall be no greater than
three and one-half and grass overgrowth.

Please contact licensing officials one corrections are
completed to schedule a final inspection visit.

Reference Playground Safety Standards.

Bathrooms - Nails shall not be accessible. Please cover/
remove from walls.

Contact your licensing official when you are ready
for Final Inspection

Amy Swartz
Center Director/Designee/Individual

Amelia Davis
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator