



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 7Date 12.7.21.

Name	<u>Thompson Head Start</u>	License No.	<u>Pending</u>
Address	<u>1038 N. Union Street, Natchez MS 39120</u>		
	Center/Organization/Individual		
Purpose	<u>P. Final</u>	Director	<u>A. Jackson</u>
Mileage Start	<u>—</u>	Mileage End	
County	<u>Adams</u>	Telephone No.	<u>601.</u>
Time In		Time Out	
		Total Time	

Findings/Comments Arrived at facility and met with director. A. Jackson Stated purpose for today's visit.

All repairs have been made to classrooms.

Kitchen is still incomplete. Once finish please notify L.O. and final inspection of Kitchen will be done.

- If the School wants to open before Kitchen repairs are complete a Catering contract with a licensed restaurant is an option.

Thanks for all you do and continue to keep safe!

Andrea Parker Jackson
Center Director/Designee/Individual

Sekeisha Sandifer
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility InspectionCounty AdamsDate 12.7.21Facility Name Thompson Head Start License Number PendingPurpose P. Final Capacity _____**All Items In Red Are Critical**

	In	Out	COS	N/A
Qualified director present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper staff to child ratio present	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Room and playground capacity met	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Center capacity met	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
License/complaint visible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Certified food manager	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Sanitation Approved

Garbage and garbage bins maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vector control maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Waste water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Food service approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Possible Monetary Penalty

	Monetary Penalty
1. _____	\$ _____
2. _____	\$ _____
3. _____	\$ _____
4. _____	\$ _____
5. _____	\$ _____

Age/Child/Staff Name

1. <u>No children Present</u>
2. _____
3. _____
4. _____
5. _____
6. _____
7. _____

Other Items - Must be corrected

	In	Out	COS	N/A
Children's belongings separated/stored	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Evacuation plans posted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Menus posted and served	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan of activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Building and Grounds

Walls, ceilings, floors, toys, equipment clean and in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
---	-------------------------------------	--------------------------	--------------------------	--------------------------

Lighting approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating/cooling approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ventilation adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Glass approved and shielded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
* Telephone on premises, available, and functioning	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Electrical outlets protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
* Large appliances located properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sinks and toilets working properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot water at all sinks, not to exceed 120°	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Children barred from kitchen	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vending machine snacks meet nutritional guidelines, if present	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exits, doors and fastening devices single action approved and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Exits unobstructed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Required smoke detectors, carbon monoxide monitors, fire extinguishers and thermometers placed properly and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

First aid kits stocked and easily accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--	-------------------------------------	--------------------------	--------------------------	--------------------------

Playground area clean, shaded, well drained and equipped and fence in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
---	-------------------------------------	--------------------------	--------------------------	--------------------------

Playground equipment meets standards	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------------------	-------------------------------------	--------------------------	--------------------------	--------------------------

Pool area clean, fenced, and adequately maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
--	--------------------------	--------------------------	--------------------------	-------------------------------------

Diaper changing stations adequate in number and each fully supplied (number _____)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--	--------------------------	--------------------------	--------------------------	--------------------------

Center Director/Individual

Andrea Park, Jackson

Child Care Representative

LeKisha Sanchez

White Copy - Facility File

Yellow Copy - Facility Operator

Mississippi State Department of Health

12-10-08

Form No. 281

Child Care Licensure Playground Checklist

Center Name Thompson Head Start Inspection Date 12.7.21

- | YES | NO | N/A | | |
|-------------------------------------|--------------------------|-------------------------------------|-----|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 1. | Playground fence less than 3 1/2" from surface. (Rule 1.11.9 (8), pg 60) In good repair, with no gaps? (Rule 1.11.9 (8), pg 60) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 2. | 2 entrances/exits, with one being remote from the building? (Rule 1.11.9 (8), pg 60) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 3. | Is surfacing adequate? If not, where is it inadequate? (CPSC, 2.4.2, pg 9-10 & 4.3) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 4. | AC units, high-voltage cabling/wires inaccessible? (Rule 1.11.9 (3), pg 59) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 5. | No standing water present on playground or in/on playground equipment or walkways? (CPSC 2.4.2.2(5), pg 10 & Rule 1.11.11 (4), pg 61) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 6. | Toys & equipment in good repair? (none broken/deteriorating) (Rule 1.10.2 (2), pg 46) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 7. | Sidewalks provide smooth walking surface? (no trip hazards) (CPSC 3.6, pg 16-17) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 8. | All bolts on equipment & fence < 2 threads beyond the nut? Are all bolts and fencing twists/wires facing away from the playground area? (Rule 1.11.9 (5), pg 59) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 9. | Tree limbs at least 7ft. above play surfaces? Is fence free of brush/overgrowth? (CPSC 3.4, 3.5, pg 16) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 10. | Are use zones adequate? If not, where are they inadequate? (CPSC 5.3.9, pg 41) |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 11. | If swings are present, are S-hooks in good repair? If not, state deficiency
(CPSC 3.2, pg 14
2.5.2, pg 1 & 5.3.8.1, pg 37) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 12. | If slide is present, is exit height/exit zone adequate? If not, state deficiency
(CPSC 5.3.6.4-5 pgs 34-35) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 13. | Are spring rockers a minimum of 6 ft. apart? (ASTM 9.5.1.2 & CPSC 5.3.7, pg 36-37) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 14. | Is age-appropriate equipment being used? If not, state which pieces are inappropriate
(Rule 1.10.2, pg 4
& CPSC 2.2.6, pg 6) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 15. | Is playground area clean & free of hazards? If not, state deficiency.
(Rule 1.11.11 (1), pg 6) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 16. | Is adequate shade present on the playground? (Rule 1.11.9 (7), pg 60 & CPSC 2.1.1, pg 5) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 17. | Are concrete footings located at least 6" beneath the surface? (Rule 1.10.2 (2), pg 46 & CPSC 3.6, pg 16-17) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 18. | Is wood smooth? Documentation provided that wood has been properly treated. (CPSC 2.5.5, pg 15) |

Director Anchia Parker Jackson Licensing Official Lekecia Sordifor