



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility Inspection

County <u>Hinds</u>	Date <u>03/21/2018</u>
Facility Name <u>Prep Company - North</u>	License Number <u>05C4PFA-0664</u>
Purpose <u>M.I.C. Year / T.A.</u>	Capacity <u>183</u>

All Items In Red Are Critical

	In	Out	COS	N/A
Qualified director present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper staff to child ratio present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Room and playground capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Center capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
License/complaint visible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Certified food manager	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Sanitation Approved

Garbage and garbage bins maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vector control maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Waste water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Food service approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Possible Monetary Penalty

	Monetary Penalty
1. _____	\$ _____
2. _____	\$ _____
3. _____	\$ _____
4. _____	\$ _____
5. _____	\$ _____

	Age/Child/Staff Name
1.	1-2 year olds (9) Caregiver #1
2.	Infants (5) Caregiver #2
3.	3-4 year olds (18) Caregiver #3
4.	_____ #4
5.	_____
6.	_____
7.	_____

Other Items - Must be corrected

	In	Out	COS	N/A
Children's belongings separated/stored	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Evacuation plans posted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Menus posted and served	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan of activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Building and Grounds

Walls, ceilings, floors, toys, equipment clean and in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lighting approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating/cooling approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ventilation adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Glass approved and shielded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Telephone on premises, available, and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical outlets protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Large appliances located properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sinks and toilets working properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot water at all sinks, not to exceed 120°	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Children barred from kitchen	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vending machine snacks meet nutritional guidelines, if present	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exits, doors and fastening devices single action approved and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exits unobstructed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Required smoke detectors, carbon monoxide monitors, fire extinguishers and thermometers placed properly and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
First aid kits stocked and easily accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground area clean, shaded, well drained and equipped and fence in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground equipment meets standards	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pool area clean, fenced, and adequately maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diaper changing stations adequate in number and each fully supplied (number <u>11</u>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Center Director/Individual

J. Rattigan

Child Care Representative

Teresa Allen



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 3 Date 03/01/2018

Name Prep Company Tutorial - North License No. 25C4PFA-0664

Address 5332 North State St Jackson MS 39206
Center/Organization/Individual

Purpose Mid-Year / T.A. Director Nora Carpenter

Mileage Start _____ Mileage End _____

County Hinds Telephone No. 601-362-4653

Time In 2:01pm Time Out 2:52pm Total Time _____

Findings/Comments Upon arrival licensing official met Ms. Jennifer Ratliff the facilities director designee. The purpose for today's visit was announced.

During the walk-through of the facility the following was observed:

Staff records are in compliance. No violations were found during the kitchen inspection today, a letter grade of "A" was issued.

Technical Assistance was given on children 121 forms. Licensing official observed 2 children with expired 121 forms. 14 days is given to submit current forms into MSDH

If you have any questions contact Lisa Allen 601-364-2827
fax: 601-364-3058
email: lisa.allen@healthms.com

A survey card was left with Ms. Ratliff

Class I and II violations may result in a monetary penalty. Repeated violations may result in the doubling of a monetary penalty, suspension, or revocation of the license.

J Ratliff
Center Director/Designee/Individual

Lisa Allen
Child Care Representative

White Copy - Facility File
Yellow Copy - Operator

Food Service Facility Inspection Results

PIMS ID	Facility Name, Address Prep Company Tutorial School - North 5332 North State St Jackson MS 39266	Date 03/21/2018
---------	--	--------------------

CRITICAL VIOLATIONS

CORRECTION PLAN AND SCHEDULE

No critical violations were found

"A" issued

<input type="checkbox"/> 92020 Scheduled <input type="checkbox"/> 92030 Followup <input type="checkbox"/> 92040 Complaint <input type="checkbox"/> 92050 Consultation <input type="checkbox"/> 92070 Plan Review/Const. <input type="checkbox"/> 92080 No Inspection <input type="checkbox"/> 92090 Restaurant Training	<input checked="" type="checkbox"/> 92010 Permit No Charge <input type="checkbox"/> 92015 Permit 1 \$30.00 <input type="checkbox"/> 92011 Permit 2 \$100.00 <input type="checkbox"/> 92012 Permit 3 \$150.00 <input type="checkbox"/> 92013 Permit 4 \$200.00
Permit Date	Environmental Code
Please Remit within 10 days to:	

Deloris Suel Tommy Sule
 Certified Manager Licence Number
 exp: 02/10/2022

Facility Signature <u>[Signature]</u>
Environmental Signature <u>[Signature]</u>

White Copy - Facility
 Yellow Copy - PIMS
 Pink Copy - Environmentalist

Child Care Licensure Playground Checklist

Center Name Prep Company Tutorial

Inspection Date 03/01/2018

YES NO N/A

- ☒ ☐ ☐ 1. Playground fence less than 3 1/2" from surface. (Rule 1.11.9 (8), pg 60) In good repair, with no gaps? (Rule 1.11.9 (8), pg 60)
- ☒ ☐ ☐ 2. 2 entrances/exits, with one being remote from the building? (Rule 1.11.9 (8), pg 60)
- ☒ ☐ ☐ 3. Is surfacing adequate? If not, where is it inadequate? (CPSC, 2.4.2, pg 9-10 & 4.3)
- ☒ ☐ ☐ 4. AC units, high-voltage cabling/wires inaccessible? (Rule 1.11.9 (5), pg 59)
- ☒ ☐ ☐ 5. No standing water present on playground or in/on playground equipment or walkways? (CPSC 2.4.2.2(5), pg 10 & Rule 1.11.11 (4), pg 61)
- ☒ ☐ ☐ 6. Toys & equipment in good repair? (none broken/deteriorating) (Rule 1.10.2 (2), pg 46)
- ☒ ☐ ☐ 7. Sidewalks provide smooth walking surface? (no trip hazards) (CPSC 3.6, pg 16-17)
- ☒ ☐ ☐ 8. All bolts on equipment & fence <2 threads beyond the nut? Are all bolts and fencing twists/wires facing away from the playground area? (Rule 1.11.9 (5), pg 59)
- ☒ ☐ ☐ 9. Tree limbs at least 7ft. above play surfaces? Is fence free of brush/overgrowth? (CPSC 3.4, 3.5, pg 16)
- ☒ ☐ ☐ 10. Are use zones adequate? If not, where are they inadequate? (CPSC 5.3.9, pg 41)
- ☐ ☐ ☒ 11. If swings are present, are S-hooks in good repair? If not, state deficiency _____ (CPSC 3.2, pg 14; 2.5.2, pg 1 & 5.3.8.1, pg 37)
- ☒ ☐ ☐ 12. If slide is present, is exit height/exit zone adequate? If not, state deficiency _____ (CPSC 5.3.6.4-5 pgs 34-35)
- ☐ ☐ ☒ 13. Are spring rockers a minimum of 6 ft. apart? (ASTM 9.5.1.2 & CPSC 5.3.7. pg 36-37)
- ☒ ☐ ☐ 14. Is age-appropriate equipment being used? If not, state which pieces are inappropriate _____ (Rule 1.10.2, pg 46 & CPSC 2.2.6, pg 6)
- ☒ ☐ ☐ 15. Is playground area clean & free of hazards? If not, state deficiency. _____ (Rule 1.11.11 (1), pg 61)
- ☒ ☐ ☐ 16. Is adequate shade present on the playground? (Rule 1.11.9 (7), pg 60 & CPSC 2.1.1, pg 5)
- ☒ ☐ ☐ 17. Are concrete footings located at least 6" beneath the surface? (Rule 1.10.2 (2), pg 46 & CPSC 3.6, pg 16-17)
- ☐ ☐ ☒ 18. Is wood smooth? Documentation provided that wood has been properly treated. (CPSC 2.5.5, pg 15)

Director

Jennifer Ratliff

Licensing Official

Jesse Allen