



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Facility Inspection

County Hinds Date 1-7-20

Facility Name The Privette School License Number 25CDRFA-3848

Purpose Mid-Year Inspection/TA Capacity 95

All Items In Red Are Critical

	In	Out	COS	N/A
Qualified director present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper staff to child ratio present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Room and playground capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Center capacity met	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
License/complaint visible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Certified food manager	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Sanitation Approved

Garbage and garbage bins maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vector control maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Waste water system approved and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Food service approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Possible Monetary Penalty

	Monetary Penalty
1. _____	\$ _____
2. _____	\$ _____
3. _____	\$ _____
4. _____	\$ _____
5. _____	\$ _____

	Age/Child/Staff Name
Rm #1	1. Infants 7 caregiver #1 & #2
Rm #2	2. Infants 6 caregiver #3 & #4
	3. Younger 1 yr olds 8 caregiver #5
	4. Older 1 yr olds 9 caregiver #6 & #7
	5. Younger 2 yr olds 11 caregiver #8 & #9
	6. 2-3 yr olds 10 caregiver #10 & #11
	7. 3-4 yr olds 9 caregiver #12
	8. School age 9 caregiver #13

Center Director/Individual

White Copy - Facility File Yellow Copy - Facility Operator

Mississippi State Department of Health

Other Items - Must be corrected

	In	Out	COS	N/A
Children's belongings separated/stored	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Evacuation plans posted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Menus posted and served	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan of activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Building and Grounds

Walls, ceilings, floors, toys, equipment clean and in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lighting approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating/cooling approved	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ventilation adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Glass approved and shielded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Telephone on premises, available, and functioning	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electrical outlets protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Large appliances located properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sinks and toilets working properly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot water at all sinks, not to exceed 120°	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Children barred from kitchen	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vending machine snacks meet nutritional guidelines, if present	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exits, doors and fastening devices single action approved and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Exits unobstructed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Required smoke detectors, carbon monoxide monitors, fire extinguishers and thermometers placed properly and in good working order	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
First aid kits stocked and easily accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground area clean, shaded, well drained and equipped and fence in good repair	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Playground equipment meets standards	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pool area clean, fenced, and adequately maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diaper changing stations adequate in number and each fully supplied (number <u>11</u>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Child Care Representative

Debbie Rose



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 5Date 1-7-20

Name	<u>The Privette School</u>	License No.	<u>25CDRFA-3848</u>
Address	<u>4419 Broadmeadow Dr. Jackson, MS 39206</u>		
Purpose	<u>Mid-Year Inspection/TA</u>	Director	<u>Tammy McGruder</u>
Mileage Start	<u>N/A</u>	Mileage End	<u>N/A</u>
County	<u>Hinds</u>	Telephone No.	<u>601-362-5545</u>
Time In	<u>2:50 pm</u>	Time Out	<u>4:45 pm</u>
		Total Time	<u>N/A</u>

Findings/Comments Upon arrival licensing official was told that the director was on an afterschool route. The director arrived at ~~2:05 pm~~ ^{2:05 pm}. Tammy McGruder arrived at 2:05 pm.

- * ~~TA~~ Recommendation provided on general cleaning of the classrooms. The restroom (toilets and sinks) need general cleaning. Rugs in some of the classrooms need to be cleaned or replaced.
- * Technical Assistance provided on adding or moving surfacing around to provide appropriate surfacing under the swings, slides, spring rockers and playground equipment. At 6-8 inches is needed under each. Additional bright highlight is needed on stumps and tree stumps on the playground to prevent tripping hazards.
- * A pest control was called to the Facility because of suspected mice. There were traps and other precautions made to prevent infestation. Licensing official didn't notice any pest droppings.
- * A staff and children roster was provided to LD.
- * The Facility has 14 days (1/21/20) to provide 8 children and 1 staff 121 forms and 2 staff Letters of Suitability.
- * A green survey card was left with the director.

Contact information 601-364-2827

Email: denise.love@healthymiss.com

"Class I and II violations may result in a monetary penalty. Repeated violations may result in the doubling of a monetary penalty, suspension, or revocation of the license."



Center Director/Designee/Individual



Child Care Representative

White Copy - Facility File
Yellow Copy - Operator

Food Service Facility Inspection Results

PIMS ID 3848	Facility Name, Address The Privette School 4419 Broadmeadow Dr. Jackson, MS 39206	Date 1-7-20
------------------------	---	-----------------------

CRITICAL VIOLATIONS

CORRECTION PLAN AND SCHEDULE

No critical violations noted.

* There were mice traps in the pantry that were placed there by pest control because of suspected mice. The facility was proactive in contacting a pest control company.

The Facility will receive letter grade "A".

<input type="checkbox"/> 92020 Scheduled	<input type="checkbox"/> 92010 Permit No Charge
<input type="checkbox"/> 92030 Followup	<input type="checkbox"/> 92015 Permit 1 \$30.00
<input type="checkbox"/> 92040 Complaint	<input type="checkbox"/> 92011 Permit 2 \$100.00
<input type="checkbox"/> 92050 Consultation	<input type="checkbox"/> 92012 Permit 3 \$150.00
<input type="checkbox"/> 92070 Plan Review/Const.	<input type="checkbox"/> 92013 Permit 4 \$200.00
<input type="checkbox"/> 92080 No Inspection	
<input type="checkbox"/> 92090 Restaurant Training	

Permit Date	Environmental Code
-------------	--------------------

Please Remit within 10 days to:

Linda Vaughn
Certified Manager

ServSafe
Licence Number

Expires 10/12/2020

Facility Signature

Environmental Signature

White Copy - Facility
Yellow Copy - PIMS
Pink Copy - Environmentalist

Child Care Licensure Playground Checklist

Center Name The Privette School Inspection Date 1-7-20

YES NO N/A

- ☒ ☐ ☐ 1. Playground fence less than 3 1/2" from surface. (Rule 1.11.9 (8), pg 60) In good repair, with no gaps? (Rule 1.11.9 (8), pg 60)
- ☒ ☐ ☐ 2. 2 entrances/exits, with one being remote from the building? (Rule 1.11.9 (8), pg 60)
- ☐ ☒ ☐ 3. Is surfacing adequate? If not, where is it inadequate? (CPSC 2.4.2, pg 9-10 & 4.3)
Recommend additional surfacing under swings, equipment, & rockers.
- ☒ ☐ ☐ 4. AC units, high-voltage cabling/wires inaccessible? (Rule 1.11.9 (5), pg 59)
- ☒ ☐ ☐ 5. No standing water present on playground or in/on playground equipment or walkways? (CPSC 2.4.2.2(5), pg 10 & Rule 1.11.11 (4), pg 61)
- ☒ ☐ ☐ 6. Toys & equipment in good repair? (none broken/deteriorating) (Rule 1.10.2 (2), pg 46)
- ☒ ☐ ☐ 7. Sidewalks provide smooth walking surface? (no trip hazards) (CPSC 3.6, pg 16-17)
- ☒ ☐ ☐ 8. All bolts on equipment & fence <2 threads beyond the nut? Are all bolts and fencing twists/wires facing away from the playground area? (Rule 1.11.9 (5), pg 59)
- ☒ ☐ ☐ 9. Tree limbs at least 7ft. above play surfaces? Is fence free of brush/overgrowth? (CPSC 3.4, 3.5, pg 16)
- ☒ ☐ ☐ 10. Are use zones adequate? If not, where are they inadequate? (CPSC 5.3.9, pg 41)
- ☒ ☐ ☐ 11. If swings are present, are S-hooks in good repair? If not, state deficiency _____ (CPSC 3.2, pg 2.5.2, pg 1 & 5.3.8.1, pg 3)
- ☒ ☐ ☐ 12. If slide is present, is exit height/exit zone adequate? If not, state deficiency _____ (CPSC 5.3.6.4-5 pg 34)
- ☒ ☐ ☐ 13. Are spring rockers a minimum of 6 ft. apart? (ASTM 9.5.1.2 & CPSC 5.3.7. pg 36-37)
- ☒ ☐ ☐ 14. Is age-appropriate equipment being used? If not, state which pieces are inappropriate _____ (Rule 1.10.2, pg 46 & CPSC 2.2.6, pg 3)
- ☐ ☒ ☐ 15. Is playground area clean & free of hazards? If not, state deficiency.
Tree stumps need to be highlighted bright colors (Rule 1.11.11 (1), pg 61)
- ☒ ☐ ☐ 16. Is adequate shade present on the playground? (Rule 1.11.9 (7), pg 60 & CPSC 2.1.1, pg 46)
- ☒ ☐ ☐ 17. Are concrete footings located at least 6" beneath the surface? (Rule 1.10.2 (2), pg 46 CPSC 3.6, pg 16-17)
- ☐ ☐ ☒ 18. Is wood smooth? Documentation provided that wood has been properly treated. (CPSC 2.5.5, pg 15)

Director [Signature]

Licensing Official [Signature]