



MISSISSIPPI STATE DEPARTMENT OF HEALTH

## Child Care Encounter

District

3

Date

8/16/2019

Name

Little Humble Hearts Christian Academy

License No.

PENDING

Address

114 S. Chester St, Ruleville MS 38771

Center/Organization/Individual

Purpose

Initial/TA

Director

Okema White

Mileage Start

Mileage End

County

Sunflower

Telephone No.

(662) 878-9832

Time In

1154 AM

Time Out

1248 PM

Total Time

Findings/Comments

The purpose for visit is for an initial inspection.

The facility was measured with a maximum capacity of (45) based on the number of bedrooms in the facility.

Facility must complete several out of compliance items listed on form # 88 before a license can be issued.

Once all items have been complete contact licensing for a final inspection.

Technical assistance was provided on all items that need to be completed for a temporary license.

A childcare survey was left with Okema White, director

Once facility has submitted all required documentation a temporary license will be issued.

Okema White

Center Director/Designee/Individual

Sara Green

Child Care Representative

White Copy - Facility File  
Yellow Copy - Operator



MISSISSIPPI STATE DEPARTMENT OF HEALTH

# Child Care Facility Data Sheet

Facility Name Little Humble Hearts Christian Academy Date 8/6/2019Physical Address 114 S. Chester St. Pulaski MS 38791Operator Diana White Daytime Telephone Number (662) 878-9832
☒ Commercial Facility    ☐ Occupied Residence    Year Building was constructed \_\_\_\_\_
Total # of Floors 1 # of Floors Used for Child Care 1 # of Rooms 6 # of Rooms Used for Child Care 4Construction: Masonry \_\_\_\_\_ Brick \_\_\_\_\_ Frame ☒ Metal \_\_\_\_\_ Other \_\_\_\_\_

## I. Building/Grounds

Mark: In = Incompliance with Regulations    Out = Out of compliance with regulations    NA = Does not apply

### A. General

- | In                                  | Out                                 | NA                                  |   |
|-------------------------------------|-------------------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 1. Two (2) easily opened outward opening doors (minimum 32 inches wide) equipped with single action opening hardware.   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 2. Walls – <input checked="" type="checkbox"/> clean <input type="checkbox"/> repair <input type="checkbox"/> paint <input type="checkbox"/> replace  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 3. Floors – <input checked="" type="checkbox"/> clean <input type="checkbox"/> repair <input type="checkbox"/> paint <input type="checkbox"/> replace   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 4. Ceiling – <input checked="" type="checkbox"/> clean <input type="checkbox"/> repair <input type="checkbox"/> paint <input type="checkbox"/> replace  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 5. Plug covers on all outlets.  |
| <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | 6. Barriers installed as needed – <input type="checkbox"/> kitchen <input type="checkbox"/> stairways <input type="checkbox"/> windows <input type="checkbox"/> porches <input type="checkbox"/> other _____  |
| <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | 7. Handrails – <input type="checkbox"/> steps <input type="checkbox"/> landings <input type="checkbox"/> toilets <input type="checkbox"/> other _____   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 8. Heating/cooling – <input checked="" type="checkbox"/> gas <input type="checkbox"/> electric <input type="checkbox"/> other _____<br>Note – Non-electric heat/cool systems or appliances require carbon monoxide monitors to be installed as well as smoke detectors. All gas heaters must be vented to outdoors. |
| <input type="checkbox"/>            | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | 9. Unapproved heaters (must be removed).  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 10. Adequate, proper heating and/or cooling systems.  |
| <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | 11. Child safe thermometers at child level in every room utilized by children.  |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | 12. Adequate lighting. Note – All lights must be shielded.  |
| <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | 13. Telephone accessible to caregivers.   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 14. Individual compartments or hooks for each child.  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 15. Diaper changing stations in all rooms housing children who are not toilet trained.<br>Note – Diaper changing stations must have hot and cold water and may not be used for any purpose except diapering. Number of diaper changing stations <u>02</u>   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 16. Approved – <input type="checkbox"/> waste water <input type="checkbox"/> water supply   |
| <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | 17. Emergency evacuation plan posted.   |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 18. Hot and cold running water at all handwashing sinks.  |
| <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/>            | 19. Building constructed prior to 1965 has been tested for lead.  |

**B. Kitchen/Food Preparation Area**

In Out NA

- ☒ ☐ ☐ 1. Adequate refrigeration with thermometer.  
☒ ☐ ☐ 2. Adequate cooking appliances (stoves/microwaves/ovens)  
 Note - Number and Type must be based on menu evaluation and number of meals to be prepared.  
☒ ☐ ☐ 3. Approved stove hood, vented to outside per fire codes.  
☒ ☐ ☐ 4. Separate freezer when 50+ children are served.  
☒ ☐ ☐ 5. Approved dishwasher. \_\_\_\_\_  
☒ ☐ ☐ 6. Three (3) compartment sink.  
☐ ☐ ☒ 7. Food preparation sink.  
☐ ☐ ☒ 8. Mop sink.  
☒ ☐ ☐ 9. Handwashing sink. Note - All sinks must have hot and cold water.

**C. Grounds**

In Out NA

- ☒ ☐ ☐ 1. Approved play area with fence.  
☒ ☐ ☐ 2. All hazards including non-approved playground equipment removed.  
☐ ☐ ☒ 3. Playground equipment approved before installation.  
☒ ☐ ☐ 4. Playground completed before opening for business.  
☒ ☐ ☐ 5. Safe arrival/departure areas.  
☒ ☐ ☐ 6. Soil tested for lead.  
☐ ☒ ☐ 7. Other Remove brush (vines) on fence

**II. Furniture And Equipment****A. Furniture**

In Out NA

- ☒ ☐ ☐ 1. Appropriate  
☒ ☐ ☐ 2. Child size  
☒ ☐ ☐ 3. Adequate number

**B. Equipment**

In Out NA

- ☒ ☐ ☐ 1. Approved location of laundry equipment  
☒ ☐ ☐ 2. Recommended toys appropriate for ages of children are available.  
☒ ☐ ☐ 3. Approved bedding - ☒ cribs ☐ cots ☐ pads

Note - 24 hour and night time care require bedding with minimum 3 inch mattresses.

**III. Other**

In Out NA

- ☒ ☐ ☐ Complies with local zoning, building and fire safety codes.

**IV. Recommendations**

*[Signature]*  
Operator/Center/Date

*[Signature]*  
Licensing Officer