



MISSISSIPPI STATE DEPARTMENT OF HEALTH

Child Care Encounter

District 5Date 6.27.19

Name	HOLY GHOST EARLY HEAD START	
Address	CENTER-Pending	
Purpose	M: P. O. BOX 22657 Jackson, MS 39225	
Mileage Start	P: 1145 CLOISTER STREET Jackson, MS	
County	39202 P. 601-923-3940	
Time In	Director	
Time Out	Mileage End	
Total Time	Telephone No.	

Findings/Comments: Initial Visit
Upon arrival the LDCs met with Micheal Escalera, Director of Facilities & Field Services and Chelsea Wister, Associate VP, H.S. and Early Childhood Programs.

The purpose of the visit is to conduct an initial visit and to provide technical assistance with the facility.

Facility will add (1) Handwashing sink and (1) Diaper changing sink in Classroom A and B and add (1) Handwashing sink only in Classroom C.

Please refer to form #286-Child Care Facility Data Sheet for all correction needs to be made before a possible final can be conducted.

Playground - Please refer to the Playground checklist for all corrections needs to be made.

Facility max capacity is 128, but facility only wants to remain at 12.

LO-left a green survey card, Complaint card with Escalera Micheal. And LO-left a business card.

[Signature]
 Center Director/Designee/Individual

[Signature]
 Child Care Representative

White Copy - Facility File
 Yellow Copy - Operator

HOLY GHOST EARLY HEAD START
CENTER-Pending
M: P. O. BOX 22657 Jackson, MS 39225
P: 1145 CLOISTER STREET Jackson, MS
39202 P. 601-923-3940

Child Care Licensure Playground Checklist

Center Name _____

Inspection Date 06.27.2019

YES NO N/A

- | | | | | |
|-------------------------------------|-------------------------------------|-------------------------------------|-----|---|
| ☐ | ☒ | ☐ | 1. | Playground fence less than 3 1/2" from surface. (Rule 1.11.9 (8), pg 60) In good repair, with no gaps? (Rule 1.11.9 (8), pg 60) |
| ☒ | ☐ | ☐ | 2. | 2 entrances/exits, with one being remote from the building? (Rule 1.11.9 (8), pg 60) |
| ☐ | ☒ | ☐ | 3. | Is surfacing adequate? If not, where is it inadequate? (CPSC 2.4.2, pg 9-10 & 4.3)
<u>needs to be replenished around play structure</u> |
| ☐ | ☒ | ☐ | 4. | AC units, <u>high-voltage</u> cabling/wires inaccessible? (Rule 1.11.9 (5), pg 59) |
| ☒ | ☐ | ☐ | 5. | No standing water present on playground or in/on playground equipment or walkways? (CPSC 2.4.2.2(5), pg 10 & Rule 1.11.11 (4), pg 61) |
| ☒ | ☐ | ☐ | 6. | Toys & equipment in good repair? (none broken/deteriorating) (Rule 1.10.2 (2), pg 46) |
| ☐ | ☒ | ☐ | 7. | Sidewalks provide smooth walking surface? (no trip hazards) (CPSC 3.6, pg 16-17) |
| ☐ | ☒ | ☐ | 8. | All bolts on equipment & fence <2 threads beyond the nut? Are all bolts and fencing twists/wires facing away from the playground area? (Rule 1.11.9 (5), pg 59) |
| ☐ | ☒ | ☐ | 9. | Tree limbs at least 7ft. above play surfaces? Is fence free of brush/overgrowth? (CPSC 3.4, 3.5, pg 16) |
| ☐ | ☒ | ☐ | 10. | Are use zones adequate? If not, where are they inadequate? (CPSC 5.3.9, pg 41) |
| ☐ | ☐ | ☒ | 11. | If swings are present, are S-hooks in good repair? If not, state deficiency
<u>2.5.2, pg 1 & 5.3.8.1, pg 37</u> |
| ☒ | ☐ | ☐ | 12. | If slide is present, is exit height/exit zone adequate? If not, state deficiency
<u>(CPSC 5.3.6.4-5 pgs 34-35)</u> |
| ☐ | ☐ | ☒ | 13. | Are spring rockers a minimum of 6 ft. apart? (ASTM 9.5.1.2 & CPSC 5.3.7. pg 36-37) |
| ☒ | ☐ | ☐ | 14. | Is age-appropriate equipment being used? If not, state which pieces are inappropriate
<u>(Rule 1.10.2, pg 4 & CPSC 2.2.6, pg 6)</u> |
| ☐ | ☒ | ☐ | 15. | Is playground area clean & free of hazards? If not, state deficiency.
<u>please see #15 that are out.</u> (Rule 1.11.11 (1), pg 6) |
| ☒ | ☐ | ☐ | 16. | Is adequate shade present on the playground? (Rule 1.11.9 (7), pg 60 & CPSC 2.1.1, pg 5) |
| ☐ | ☒ | ☐ | 17. | Are concrete footings located at least 6" beneath the surface? (Rule 1.10.2 (2), pg 46 & CPSC 3.6, pg 16-17) |
| ☒ | ☐ | ☐ | 18. | Is wood smooth? Documentation provided that wood has been properly treated. (CPSC 2.5.5, pg 15) |

Director _____

Licensing Official _____

Azelda Cee
Monica Davis
Opal W. W. W. W.