



MISSISSIPPI STATE DEPARTMENT OF HEALTH

COS-Corrected on Site  
TA-Technical Assistance  
POC-Plan of Correction  
LOS-Letter of Suitability

Page 1 of 1

## Child Care Encounter

District 5

Date 2.21.2020

|                               |                                      |                  |
|-------------------------------|--------------------------------------|------------------|
| Name _____                    | License No. _____                    |                  |
| Address _____                 | Center/Organization/Individual _____ |                  |
| Purpose <u>Follow-up / TA</u> | Director _____                       |                  |
| Mileage Start _____           | Mileage End _____                    |                  |
| County <u>Hinds</u>           | Telephone No. _____                  |                  |
| Time In <u>2:15 am</u>        | Time Out <u>3:00 p.m.</u>            | Total Time _____ |

Findings/Comments Upon arrival the LO. met with the designee Beverly Baggett.

The purpose of the visit is to conduct a follow-up on water dripping from light in the girls restroom.

Director stated that she would have a contractor to come out to assess the leaking, by Monday, February 17, 2020. LO. received an email on Saturday, February 15, 2020 confirming that the contractor came out and assessed the leaking water coming from the light. It was over flowing from hot water heater. Corrections were made on February 16, 2020 and an invoice was email as well.

On today's visit, the LO. notice corrections was made and it appear that no water is leaking from the light. LO. take a picture of the light.

Class I II violations may result in a monetary penalty.

Repeated violations may result in the doubling of a monetary penalty,

suspension or revocation of license.

A green survey card was left with, designee Beverly Baggett.

B. Blackmon  
Center Director/Designee/Individual

Azula Eeeli  
Child Care Representative

White Copy - Facility File  
Yellow Copy - Operator